

For release            By Major A. H. Thiessen  
July 2, 1940        Science Service Meteorologist

Protection from lightning! In providing protection by rods, it is best to consult an expert who will be governed by an authorized code, but a few hints may be useful to satisfy one of a good job. For instance: on any building there must be air terminals (pointed rods) for all projections likely to receive a stroke as chimneys and ventilators; there must be at least two down conductors; all metal roofs or other large metal attachments must be bonded to the conductors; and each down conductor must be well grounded. Grounding is best done on metal water pipes or other large buried piece of metal, preferably in moist ground.

-----